

**1. What role do you see for the still less popular fabric diffusers / ducting in providing high IAQ for treatment facilities?**

- *Fabric ducting and daily cleaning is not possible.*
- *Electrical induction can be an issue.*
- *How to integrate HEPA filters behind fabric ducts. And flow?*
- *Why choose different solutions if they give problems?*
- *Use a risk based approach.*